

ELECTRICAL FINAL

ALL CODE REFERENCES ARE 2008 N.E.C. UNLESS OTHERWISE NOTED

GENERAL

- * **ALL** FIXTURES MUST BE **LISTED AND** SUITABLE FOR LOCATION USED. (410-6 & 410.10)
- * INCANDESCENT CLOSET FIXTURES MUST BE GLOBE TYPE AND INSTALLED 12" HORIZONTALLY FROM THE EDGE OF SHELF. (410-16)
- * CONDUCTIVE PARTS MUST BE GROUNDED. (410-40 & 410.42 410.44)
- * MUST HAVE A SWITCHED LIGHT OR RECEPTACLE IN EACH HABITABLE ROOM. (210-70a)
- * MUST HAVE A SWITCHED LIGHT AT OUTDOOR ENTRANCE. (210-70a2)
- * BELL TRANSFORMERS MUST BE ACCESSIBLE (NOT INSTALLED INSIDE ELECTRICAL PANELS **OR ATTICS**) (110.2 & .3(A&B))
- * **ALL 120 V, 15-20 AMP RECEPTICLES SHALL BE LISTED TAMPER RESISTANT PER ART. 210.52 (406.11)**
- * **ALL 120 V 15-20 AMP BRANCH CIRCUITS IN BEDROOMS, FAMILY ROOMS, DINING ROOMS, LIVING ROOMS, RECREATION ROOMS, LIBRARIES, DENS, PARLORS, SUNROOMS, HALLWAYS, CLOSETS AND SIMILAR ROOMS OR AREAS SHALL BE AFCI PROTECTED. (210.12 (B))**
- * **A TOTALLY ENCLOSED WEATHERPROOF OUTLET COVER WHICH REMAINS WEATHERPROOF WITH THE CORD ATTACHED MUST BE USED ON ALL 15-20 AMP / 120-250 VOLT RECEPTICLES INSTALLED IN WET LOCATIONS. (406.8(B))**
- * **ALL 15-20 AMP / 120 250 VOLT NON LOCKING RECEPTICLES INSTALLED IN DAMP OR WET LOCATIONS MUST BE LISTED WEATHER RESISTANT TYPE. (406.8(A))**
- * **SMOKE DETECTORS (AND CARBON MONOXIDE DETECTORS WHEN REQUIRED) ARE IN PROPER LOCATIONS AND INSTALLED PER MANUFACTURES REQUIREMENTS**

ENCLOSURES

- * PANEL MUST BE LABELED WITH ELECTRICIAN'S NAME AND ADDRESS. ALL CIRCUITS MUST BE IDENTIFIED **AND SPARE BREAKERS MUST BE MARKED ACCORDINGLY.** (110-21 & 408.4)
- * OPEN KNOCKOUTS MUST BE SEALED. (312.5(A)&110.12(A))
- * ALL COVERS AND PLATES MUST BE INSTALLED. (404.9)
- * ALL SWITCHES AND RECEPTACLES MUST BE GROUNDED. (404.9(B), 404.12 & 406.3(A) & (B))
- * IF METAL CONDUIT IS USED TO PROTECT SERVICE ENTRANCE CONDUCTORS, A BONDING BUSHING MUST BE USED IF THE LARGEST CONCENTRIC OR ECCENTRIC KNOCKOUT HAS NOT BEEN PUNCHED OUT. (250-92 B)
- * RETURN PLANS TO ORIGINAL LOCATION, SIGN AND DATE PERMIT CARD, **OR LEAVE CORRECTION NOTICE WITH ITEMS LISTED**

THIS LIST IS A GUIDE ONLY AND IS NOT ALL ENCOMPASSING